

(2023.11.13. revised)

# Comparison Evaluation of SMD type Aluminum Electrolytic Capacitors

面実装型電解コンデンサ試験結果報告Vol.2



# Table of Contents

I. Introduction

II. Environmental test (raw data, graphs)


III. X-ray analyses

IV. SEM analyses

V. Summary and conclusions



# Specimens



Sample	Capacitance ( $\mu\text{F}$ ) ( $\pm 10\%$ )	Rated voltage ( $V_{\text{DC}}$ )	Capacitance tolerance (%)	Shelf life (Hr)	Operation Temp. ( $^{\circ}\text{C}$ )	Dimensions (mm)
A	100	50	$\pm 20$	1000 Hr at $105^{\circ}\text{C}$	-55 ~ +105	$\Phi 10 \times 10$
B	100	50	$\pm 20$	1000 Hr at $105^{\circ}\text{C}$	-55 ~ +105	$\Phi 8 \times 10$
C	100	50	$\pm 20$	1000 Hr at $105^{\circ}\text{C}$	-55 ~ +105	$\Phi 8 \times 10$

- A社 : SAMWHA (韓国) (RC1H107M10010)
- B社 : SU'SCON (台湾) (CH050M101F10PKKKV00R)
- C社 : NICHICON (日本) (UWT1H101MNL1GS)

## **II. Environmental test ~**

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	98.9019	98.3452	-0.562881	0.050808	0.048203	-5.127145	0.685290	0.649850	-5.171533
2	99.4635	99.0922	-0.373303	0.050847	0.047271	-7.032863	0.681300	0.628010	-7.821811
3	100.551	99.7579	-0.788754	0.050319	0.048764	-3.090284	0.664650	0.646810	-2.684119
4	98.5208	97.8814	-0.649000	0.052205	0.050474	-3.315774	0.696490	0.681120	-2.206780
5	99.9911	99.4052	-0.585952	0.049807	0.047151	-5.332584	0.656770	0.627790	-4.412504
6	100.507	99.9324	-0.571701	0.048566	0.046253	-4.762591	0.639990	0.611910	-4.387569
7	99.1683	98.5295	-0.644157	0.046947	0.045104	-3.925703	0.627160	0.606460	-3.300593
8	101.068	100.335	-0.725254	0.044829	0.042978	-4.129024	0.589040	0.565260	-4.037077
9	97.9175	97.3167	-0.613578	0.050123	0.047949	-4.337330	0.680590	0.653180	-4.027388
10	100.078	99.4922	-0.585343	0.051886	0.049763	-4.091662	0.682330	0.658520	-3.489514
Min	97.9175	97.3167	-0.613578	0.044829	0.042978	-4.129024	0.589040	0.565260	-4.037077
Max	101.068	100.335	-0.725254	0.052205	0.050474	-3.315774	0.696490	0.681120	-2.206780
Avg	99.6167	99.0088	-0.610279	0.049634	0.047391	-4.518503	0.660361	0.632891	-4.159846

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	99.2494	98.9928	-0.258541	0.050529	0.052879	4.650795	0.675840	0.707240	4.646070
2	99.6261	99.6972	0.071367	0.053288	0.054081	1.488140	0.700070	0.716010	2.276915
3	100.802	100.701	-0.100196	0.048923	0.050625	3.478936	0.641810	0.665390	3.673985
4	97.0514	96.9893	-0.063987	0.051525	0.053233	3.314896	0.704820	0.723980	2.718425
5	97.6265	97.6036	-0.023457	0.052206	0.053511	2.499713	0.704510	0.726490	3.119899
6	99.8175	99.7504	-0.067223	0.056198	0.057846	2.932489	0.741180	0.765210	3.242127
7	100.205	100.413	0.207574	0.057202	0.057227	0.043705	0.753120	0.754210	0.144731
8	99.1915	98.9246	-0.269075	0.050374	0.052947	5.107794	0.674160	0.706240	4.758514
9	100.502	100.471	-0.030845	0.045696	0.046654	2.096464	0.601170	0.614170	2.162450
10	99.5474	99.4842	-0.063487	0.051462	0.053104	3.190704	0.683170	0.704120	3.066587
Min	97.0514	96.9893	-0.063987	0.045696	0.046654	2.096464	0.601170	0.614170	2.162450
Max	100.802	100.701	-0.100196	0.057202	0.057846	1.125835	0.753120	0.765210	1.605322
Avg	99.3619	99.3027	-0.059550	0.05174	0.053211	2.841885	0.687985	0.708306	2.953698

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	97.5531	97.2053	-0.356524	0.046851	0.048313	3.120531	0.632760	0.657640	3.931981
2	99.1395	99.0242	-0.116301	0.047251	0.048199	2.006307	0.630630	0.643180	1.990073
3	99.2261	99.0915	-0.135650	0.049398	0.050885	3.010243	0.657610	0.678880	3.234440
4	100.580	100.556	-0.023862	0.051643	0.052297	1.266387	0.679940	0.686730	0.998618
5	100.109	100.026	-0.082910	0.049240	0.049954	1.450041	0.650020	0.660920	1.676871
6	98.5103	98.6037	0.094812	0.058929	0.059821	1.513686	0.794170	0.799450	0.664845
7	100.673	100.569	-0.103305	0.041346	0.042495	2.778987	0.566320	0.559790	-1.153058
8	99.6298	99.5918	-0.038141	0.053165	0.054451	2.418885	0.705350	0.722060	2.369037
9	98.7614	98.7628	0.001418	0.058346	0.058894	0.939225	0.779440	0.788360	1.144411
10	98.8416	98.9105	0.069707	0.053764	0.054321	1.036009	0.719160	0.721720	0.355971
Min	97.5531	97.2053	-0.356524	0.041346	0.042495	2.778987	0.566320	0.559790	-1.153058
Max	100.673	100.569	-0.103305	0.058929	0.059821	1.513686	0.794170	0.799450	0.664845
Avg	99.3024	99.2341	-0.068780	0.050993	0.051963	1.901622	0.681540	0.691873	1.516125

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	100.082	99.9699	-0.112008	0.047986	0.049072	2.263160	0.632360	0.650470	2.863875
2	100.071	99.9198	-0.151093	0.048719	0.050053	2.738151	0.644480	0.662130	2.738642
3	99.9607	99.9391	-0.021608	0.051558	0.052199	1.243260	0.680860	0.692020	1.639103
4	100.234	100.12	-0.113734	0.049643	0.050635	1.998268	0.655210	0.667650	1.898628
5	100.365	100.135	-0.229164	0.049849	0.051804	3.921844	0.655140	0.684490	4.479958
6	100.011	99.8752	-0.135785	0.051278	0.052355	2.100316	0.678140	0.691870	2.024656
7	99.7564	99.7305	-0.025963	0.050192	0.050903	1.416560	0.664070	0.678230	2.132305
8	99.4196	99.2309	-0.189802	0.048175	0.049948	3.680332	0.641670	0.664710	3.590631
9	99.5585	99.4073	-0.151871	0.052647	0.054112	2.782685	0.698140	0.719320	3.033775
10	99.5338	99.3467	-0.187976	0.047946	0.049555	3.355859	0.637580	0.658670	3.307820
Min	99.4196	99.2309	-0.189802	0.047946	0.049072	2.348475	0.632360	0.650470	2.863875
Max	100.365	100.135	-0.229164	0.052647	0.054112	2.782685	0.698140	0.719320	3.033775
Avg	99.8992	99.7674	-0.131893	0.049799	0.051064	2.538791	0.658765	0.676956	2.761379



\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	98.1053	97.9839	-0.123745	0.052221	0.052768	1.047471	0.702510	0.714910	1.765099
2	100.424	99.8819	-0.539811	0.048987	0.051813	5.768877	0.648860	0.684990	5.568227
3	99.4979	99.4083	-0.090052	0.051119	0.051651	1.040709	0.678640	0.687940	1.370388
4	99.3859	99.1763	-0.210895	0.052799	0.054224	2.698915	0.703170	0.721080	2.547037
5	99.2654	99.1503	-0.115952	0.054374	0.054996	1.143929	0.723600	0.735530	1.648701
6	99.6528	99.3849	-0.268833	0.051218	0.052726	2.944277	0.681030	0.700690	2.886804
7	99.5556	99.4224	-0.133795	0.050548	0.051167	1.224579	0.670980	0.682030	1.646845
8	99.7863	99.6047	-0.181989	0.056018	0.057272	2.238566	0.741430	0.759040	2.375140
9	99.6229	99.4951	-0.128284	0.051047	0.051648	1.177346	0.677170	0.687260	1.490025
10	100.525	100.336	-0.188013	0.048233	0.049317	2.247424	0.635290	0.649490	2.235200
Min	98.1053	97.9839	-0.123745	0.048233	0.049317	2.247424	0.635290	0.649490	2.235200
Max	100.525	100.336	-0.188013	0.056018	0.057272	2.238566	0.741430	0.759040	2.375140
Avg	99.5821	99.3844	-0.198560	0.051656	0.052758	2.132940	0.686268	0.702296	2.335531

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	90.4254	90.7023	0.306219	0.225466	0.205411	-8.894911	0.378170	0.344940	-8.787053
2	90.7108	92.7730	2.273379	0.231813	0.196716	-15.140221	0.385160	0.330920	-14.082459
3	92.0519	91.9241	-0.138835	0.223405	0.208741	-6.563864	0.365410	0.345510	-5.445937
4	89.7927	89.3494	-0.493693	0.227895	0.216202	-5.130872	0.386520	0.368470	-4.669875
5	91.6985	91.5802	-0.129010	0.226752	0.211136	-6.886819	0.375850	0.350330	-6.789943
6	92.5755	92.8122	0.255683	0.219850	0.200794	-8.667728	0.359170	0.331920	-7.586937
7	91.8635	91.8212	-0.046047	0.209473	0.195368	-6.733565	0.346070	0.325550	-5.929436
8	93.9825	94.1613	0.190248	0.209891	0.190771	-9.109490	0.338670	0.312770	-7.647563
9	89.5191	89.6513	0.147678	0.227267	0.208716	-8.162646	0.382410	0.353710	-7.505034
10	91.7142	91.8104	0.104891	0.223496	0.209111	-6.436357	0.375890	0.352720	-6.164037
Min	89.5191	89.3494	-0.189568	0.209473	0.190771	-8.928120	0.338670	0.312770	-7.647563
Max	93.9825	94.1613	0.190248	0.231813	0.216202	-6.734307	0.386520	0.368470	-4.669875
Avg	91.4334	91.6585	0.246223	0.222531	0.204297	-8.194012	0.369332	0.341684	-7.485948

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	90.8862	90.1501	-0.809914	0.223329	0.239126	7.073421	0.370070	0.397770	7.485070
2	90.5402	90.1436	-0.438037	0.238071	0.252026	5.861697	0.397270	0.421030	5.980819
3	92.3007	91.7185	-0.630764	0.225721	0.239338	6.032669	0.366740	0.391520	6.756830
4	88.5676	88.1827	-0.434583	0.224295	0.237884	6.058539	0.382790	0.407510	6.457849
5	89.2138	88.4103	-0.900645	0.224743	0.245103	9.059237	0.382750	0.415060	8.441541
6	89.9903	89.0531	-1.041446	0.243781	0.265448	8.887895	0.409080	0.443320	8.370001
7	89.5619	89.3663	-0.218396	0.249371	0.266876	7.019661	0.417050	0.440640	5.656396
8	90.7801	90.0199	-0.837408	0.223855	0.240515	7.442318	0.370760	0.402860	8.657892
9	93.2873	92.8084	-0.513360	0.211325	0.222095	5.096415	0.345730	0.361730	4.627889
10	91.0113	90.5434	-0.514112	0.226403	0.237979	5.113006	0.375420	0.396610	5.644345
Min	88.5676	88.1827	-0.434583	0.211325	0.222095	5.096415	0.345730	0.361730	4.627889
Max	93.2873	92.8084	-0.513360	0.249371	0.266876	7.019661	0.417050	0.443320	6.299005
Avg	90.6139	90.0396	-0.633799	0.229089	0.244639	6.787569	0.381766	0.407805	6.820670

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	91.1158	89.5002	-1.773128	0.200705	0.222127	10.673376	0.343350	0.375380	9.328673
2	91.5666	91.0306	-0.585366	0.218753	0.225881	3.258470	0.361980	0.376010	3.875905
3	91.3011	90.5187	-0.856945	0.219811	0.229767	4.529346	0.365710	0.382550	4.604741
4	91.6541	91.2805	-0.407620	0.232711	0.241036	3.577399	0.382220	0.398510	4.261943
5	92.1251	91.5621	-0.611126	0.224155	0.231873	3.443153	0.369090	0.381440	3.346067
6	87.6826	87.1415	-0.617112	0.250818	0.273125	8.893700	0.426110	0.464520	9.014104
7	94.1301	94.0021	-0.135982	0.203455	0.203628	0.085031	0.331110	0.330240	-0.262753
8	90.7015	90.0113	-0.760958	0.233500	0.249093	6.677944	0.387610	0.415490	7.192797
9	88.0222	87.1804	-0.956350	0.259198	0.277603	7.100749	0.439870	0.469410	6.715621
10	89.8622	89.5651	-0.330617	0.234962	0.243871	3.791677	0.393320	0.409990	4.238279
Min	87.6826	87.1415	-0.617112	0.200705	0.203628	1.456366	0.331110	0.330240	-0.262753
Max	94.1301	94.0021	-0.135982	0.259198	0.277603	7.100749	0.439870	0.469410	6.715621
Avg	90.8161	90.1793	-0.701285	0.227807	0.2398	5.264812	0.380037	0.400354	5.346058

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	92.1316	91.4498	-0.740028	0.223845	0.234511	4.764904	0.368720	0.385910	4.662074
2	92.1129	91.6891	-0.460088	0.221976	0.228507	2.942210	0.364430	0.377450	3.572703
3	91.0775	90.6196	-0.502759	0.233434	0.241202	3.327707	0.387550	0.398730	2.884789
4	91.9831	91.6981	-0.309840	0.228812	0.232601	1.655945	0.374720	0.383650	2.383113
5	92.0626	91.1023	-1.043095	0.222674	0.237211	6.528378	0.367670	0.391420	6.459597
6	91.8212	91.4804	-0.371156	0.223431	0.228861	2.430280	0.368030	0.378620	2.877483
7	91.3087	90.7235	-0.640903	0.229568	0.238638	3.950899	0.381030	0.394120	3.435425
8	91.5208	91.0222	-0.544794	0.223671	0.232118	3.776529	0.368140	0.385270	4.653121
9	90.5261	89.8224	-0.777345	0.233428	0.244796	4.870024	0.389750	0.408030	4.690186
10	91.7909	91.2873	-0.548638	0.219878	0.227011	3.244072	0.362770	0.378010	4.201009
Min	90.5261	89.8224	-0.777345	0.219878	0.227011	3.244072	0.362770	0.377450	4.046641
Max	92.1316	91.6981	-0.470523	0.233434	0.244796	4.867329	0.389750	0.408030	4.690186
Avg	91.6335	91.0895	-0.593745	0.226072	0.234546	3.748324	0.373281	0.388121	3.975557

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	89.3357	88.7898	-0.611066	0.232665	0.239125	2.776524	0.393930	0.403770	2.497906
2	91.9013	91.0016	-0.978985	0.225316	0.236085	4.779510	0.366940	0.392140	6.867608
3	91.0514	90.5911	-0.505539	0.230211	0.236017	2.522034	0.382110	0.390960	2.316087
4	90.2049	89.8147	-0.432571	0.237118	0.241499	1.847603	0.395150	0.405440	2.604074
5	90.0296	89.5808	-0.498503	0.235124	0.240315	2.207771	0.394010	0.402280	2.098931
6	90.8007	90.3059	-0.544930	0.234914	0.240713	2.468563	0.389360	0.401950	3.233511
7	91.5176	90.9862	-0.580653	0.222855	0.229810	3.120863	0.370010	0.380460	2.824248
8	89.5822	89.1111	-0.525886	0.248315	0.253383	2.040956	0.414840	0.425850	2.654035
9	91.0689	90.6612	-0.447683	0.228761	0.233912	2.251695	0.379980	0.388150	2.150113
10	92.5675	92.1773	-0.421530	0.223571	0.228543	2.223902	0.365330	0.375440	2.767361
Min	89.3357	88.7898	-0.611066	0.222855	0.228543	2.552332	0.365330	0.375440	2.767361
Max	92.5675	92.1773	-0.421530	0.248315	0.253383	2.040956	0.414840	0.425850	2.654035
Avg	90.8060	90.3020	-0.555041	0.231885	0.23794	2.611294	0.385166	0.396644	2.980014

No.	Leakage current (nA)					
	Before Test	After 200 hr	After 400 hr	After 600 hr	After 800 hr	After 1000 hr
1	2	2	2	2	2	2
2	2	2	1	2	2	2
3	2	2	2	2	2	2
4	2	2	2	2	2	2
5	2	2	1	2	2	2
6	2	2	2	2	2	2
7	2	2	2	2	2	2
8	2	2	2	2	2	2
9	2	2	2	2	2	2
10	2	2	2	2	2	2

No.	Leakage current (nA)					
	Before Test	After 200 hr	After 400 hr	After 600 hr	After 800 hr	After 1000 hr
1	2	2	1	3	2	2
2	2	2	1	3	2	2
3	2	2	1	3	2	2
4	2	2	1	3	2	2
5	2	2	1	2	2	2
6	2	2	1	3	2	2
7	2	2	1	2	2	2
8	2	2	1	2	2	2
9	2	2	1	2	2	2
10	2	2	1	2	2	2



\* \*印加電圧: 500Vdc

Original sample			After the high temperature test sample		
No.	Leakage current (uA)	Withstanding voltage (PASS/FAIL)	No.	Leakage current (uA)	Withstanding voltage (PASS/FAIL)
1	1	PASS	11	1	PASS
2	1	PASS	12	1	PASS
3	1	PASS	13	1	PASS
4	1	PASS	14	1	PASS
5	1	PASS	15	1	PASS
6	1	PASS			
7	1	PASS			
8	1	PASS			
9	1	PASS			
10	1	PASS			

\* \*印加電圧: 500Vdc

Original sample		After the high temperature test sample	
No.	Insulation resistance(MΩ)	No.	Insulation resistance(MΩ)
1	Over 100	11	Over 100
2	Over 100	12	Over 100
3	Over 100	13	Over 100
4	Over 100	14	Over 100
5	Over 100	15	Over 100
6	Over 100		
7	Over 100		
8	Over 100		
9	Over 100		
10	Over 100		

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	93.6066	93.0811	-0.561392	0.053834	0.051953	-3.494074	0.763880	0.740350	-3.080327
2	93.9321	93.3966	-0.570093	0.050967	0.048208	-5.413307	0.716170	0.682360	-4.720946
3	93.1449	92.5313	-0.658759	0.055081	0.053904	-2.136853	0.784420	0.771900	-1.596084
4	95.2706	94.9551	-0.331162	0.047529	0.043923	-7.586947	0.657730	0.611650	-7.005914
5	94.1454	93.5375	-0.645703	0.050584	0.047636	-5.827930	0.712110	0.675330	-5.164932
6	94.6083	94.3632	-0.259068	0.046448	0.042862	-7.720462	0.648130	0.599850	-7.449123
7	95.2526	94.9422	-0.325870	0.047294	0.043733	-7.529496	0.658740	0.610480	-7.326107
8	93.9368	93.3888	-0.583371	0.052814	0.050037	-5.258076	0.741120	0.707660	-4.514788
9	95.3501	94.8593	-0.514735	0.048227	0.045432	-5.795509	0.670770	0.636830	-5.059857
10	94.2225	93.8113	-0.436414	0.046616	0.043531	-6.617899	0.652960	0.613190	-6.090725
Min	93.1449	92.5313	-0.658759	0.046448	0.042862	-7.720462	0.648130	0.599850	-7.449123
Max	95.3501	94.9551	-0.414263	0.055081	0.053904	-2.136853	0.784420	0.771900	-1.596084
Avg	94.3470	93.8866	-0.487933	0.049939	0.047122	-5.641838	0.700603	0.664960	-5.087475

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	95.2542	95.2829	0.030130	0.047311	0.047323	0.025364	0.659250	0.658650	-0.091013
2	93.1987	93.2526	0.057833	0.054155	0.054131	-0.044317	0.766420	0.765640	-0.101772
3	93.5129	93.5278	0.015934	0.055394	0.055518	0.223851	0.785360	0.785970	0.077671
4	94.6173	94.5626	-0.057812	0.048553	0.048686	0.273927	0.677720	0.679620	0.280352
5	94.8423	94.6819	-0.169123	0.049331	0.050544	2.458900	0.690530	0.706300	2.283753
6	94.8023	94.7808	-0.022679	0.046864	0.047303	0.936753	0.652520	0.660060	1.155520
7	95.0806	95.0506	-0.031552	0.046321	0.046844	1.129078	0.646490	0.652220	0.886325
8	94.1439	94.1685	0.026130	0.054292	0.054355	0.116039	0.760520	0.762620	0.276127
9	94.1603	93.9756	-0.196155	0.049928	0.051125	2.397452	0.702640	0.719950	2.463566
10	94.2833	94.2595	-0.025243	0.048458	0.047975	-0.996739	0.664550	0.672780	1.238432
Min	93.1987	93.2526	0.057833	0.046321	0.046844	1.129078	0.646490	0.652220	0.886325
Max	95.2542	95.2829	0.030130	0.055394	0.055518	0.223851	0.785360	0.785970	0.077671
Avg	94.3896	94.3543	-0.037398	0.050061	0.05038	0.638625	0.700600	0.706381	0.825150

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	94.3954	93.7925	-0.638696	0.048645	0.050094	2.978723	0.688500	0.707820	2.806100
2	94.4953	93.8991	-0.630931	0.047151	0.048208	2.241734	0.657680	0.678130	3.109415
3	95.4177	95.0714	-0.362931	0.046937	0.046811	-0.268445	0.652530	0.652460	-0.010727
4	95.0848	94.7719	-0.329075	0.046748	0.046414	-0.714469	0.648640	0.647370	-0.195794
5	94.6813	94.1923	-0.516469	0.045888	0.046284	0.862971	0.643740	0.651330	1.179047
6	93.3620	93.2622	-0.106896	0.052569	0.051126	-2.744964	0.742850	0.723840	-2.559063
7	95.0366	94.2552	-0.822210	0.046903	0.048321	3.023261	0.655420	0.680130	3.770102
8	94.4831	94.2813	-0.213583	0.046508	0.045773	-1.580373	0.647410	0.641880	-0.854173
9	94.0102	93.7881	-0.236251	0.053049	0.052436	-1.155535	0.747720	0.740560	-0.957578
10	95.1511	94.6408	-0.536305	0.045099	0.046197	2.434644	0.622240	0.645050	3.665788
Min	93.362	93.2622	-0.106896	0.045099	0.045773	1.494490	0.622240	0.641880	3.156338
Max	95.4177	95.0714	-0.362931	0.053049	0.052436	-1.155535	0.747720	0.740560	-0.957578
Avg	94.6118	94.1955	-0.439977	0.04795	0.048166	0.451932	0.670673	0.676857	0.922059

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	95.8121	95.8271	0.015656	0.048303	0.048565	0.542409	0.668230	0.671870	0.544723
2	95.3945	95.3845	-0.010483	0.050112	0.050543	0.860073	0.692840	0.700060	1.042088
3	95.3703	95.3473	-0.024117	0.046074	0.046603	1.148153	0.641940	0.648310	0.992305
4	93.8434	93.8307	-0.013533	0.054221	0.054399	0.328286	0.761330	0.764080	0.361210
5	95.3712	95.3442	-0.028310	0.047049	0.047448	0.848052	0.654650	0.659550	0.748492
6	95.3404	95.3461	0.005979	0.048757	0.049009	0.516849	0.674620	0.678680	0.601820
7	95.8201	95.8287	0.008975	0.046673	0.046922	0.533499	0.646070	0.649120	0.472085
8	95.4489	95.4855	0.038345	0.047435	0.047465	0.063244	0.655740	0.655870	0.019825
9	94.2589	94.3041	0.047953	0.050222	0.050403	0.360400	0.706060	0.708740	0.379571
10	96.1055	96.1002	-0.005515	0.048013	0.048405	0.816446	0.659210	0.663770	0.691737
Min	93.8434	93.8307	-0.013533	0.046074	0.046603	1.148153	0.641940	0.648310	0.992305
Max	96.1055	96.1002	-0.005515	0.054221	0.054399	0.328286	0.761330	0.764080	0.361210
Avg	95.2765	95.2798	0.003474	0.048686	0.048976	0.596271	0.676069	0.680005	0.582189

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	93.4482	93.5205	0.077369	0.053154	0.052435	-1.352673	0.752750	0.743110	-1.280638
2	95.0061	94.9765	-0.031156	0.045801	0.045839	0.082968	0.636730	0.638020	0.202598
3	93.3847	93.2645	-0.128715	0.053539	0.053787	0.463214	0.760830	0.763480	0.348304
4	94.9887	94.9445	-0.046532	0.046517	0.046613	0.206376	0.646670	0.648590	0.296906
5	95.2943	95.2209	-0.077025	0.047331	0.047812	1.016247	0.659540	0.665240	0.864239
6	95.7227	95.6881	-0.036146	0.047032	0.047108	0.161592	0.648850	0.650140	0.198813
7	93.1561	93.0566	-0.106810	0.057221	0.057229	0.013981	0.816950	0.814010	-0.359875
8	94.9141	94.8607	-0.056261	0.047085	0.047312	0.482107	0.654420	0.659340	0.751811
9	94.6794	94.6503	-0.030735	0.050653	0.050711	0.114505	0.710620	0.709840	-0.109763
10	94.1108	94.0088	-0.108383	0.047779	0.048502	1.513217	0.669610	0.682250	1.887666
Min	93.1561	93.0566	-0.106810	0.045801	0.045839	0.082968	0.636730	0.638020	0.202598
Max	95.7227	95.6881	-0.036146	0.057221	0.057229	0.013981	0.816950	0.814010	-0.359875
Avg	94.4705	94.4191	-0.054377	0.049611	0.049735	0.249137	0.695697	0.697402	0.245078

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	83.4631	83.9767	0.615362	0.293613	0.271454	-7.547009	0.512610	0.478120	-6.728312
2	84.8931	85.4105	0.609472	0.278915	0.257921	-7.527024	0.488500	0.451580	-7.557830
3	82.4817	82.7013	0.266241	0.304818	0.282945	-7.175757	0.535530	0.502960	-6.081825
4	86.1801	86.8165	0.738454	0.276935	0.258444	-6.677018	0.477180	0.444810	-6.783604
5	84.6468	85.2701	0.736354	0.285426	0.262616	-7.991563	0.494940	0.456830	-7.699923
6	85.8001	86.6241	0.960372	0.272864	0.252055	-7.626143	0.472770	0.436640	-7.642194
7	85.7916	86.7041	1.063624	0.282519	0.260063	-7.948492	0.483250	0.446380	-7.629591
8	84.5914	85.1251	0.630915	0.281909	0.260253	-7.681912	0.493840	0.457090	-7.441682
9	86.0501	86.8437	0.922253	0.280516	0.253251	-9.719588	0.478710	0.433170	-9.513066
10	85.5315	86.1657	0.741481	0.271410	0.250212	-7.810324	0.473250	0.436220	-7.824617
Min	82.4817	82.7013	0.266241	0.27141	0.250212	-7.810324	0.472770	0.433170	-8.376166
Max	86.1801	86.8437	0.770015	0.304818	0.282945	-7.175757	0.535530	0.502960	-6.081825
Avg	84.9430	85.5638	0.730879	0.282893	0.260921	-7.766590	0.491058	0.454380	-7.469179



\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	85.7876	85.8636	0.088591	0.282614	0.282133	-0.170197	0.483830	0.482530	-0.268689
2	83.6442	83.6972	0.063364	0.287633	0.287290	-0.119249	0.509540	0.507040	-0.490639
3	82.9622	83.1202	0.190448	0.303007	0.301177	-0.603946	0.530380	0.527560	-0.531694
4	85.5364	85.5429	0.007599	0.276718	0.275745	-0.351622	0.479920	0.478230	-0.352142
5	85.4841	85.1962	-0.336788	0.281975	0.285183	1.137690	0.482750	0.492510	2.021750
6	85.8441	85.5299	-0.366012	0.276491	0.281894	1.954132	0.477750	0.486360	1.802198
7	86.0136	85.9061	-0.124980	0.276181	0.278354	0.786803	0.473110	0.478060	1.046268
8	84.4819	84.1564	-0.385290	0.286199	0.292317	2.137673	0.500290	0.509760	1.892902
9	84.8707	84.5249	-0.407443	0.278936	0.282707	1.351923	0.483350	0.492510	1.895107
10	85.3525	84.8926	-0.538824	0.275603	0.283464	2.852291	0.480750	0.492410	2.425377
Min	82.9622	83.1202	0.190448	0.275603	0.275745	0.051523	0.473110	0.478060	1.046268
Max	86.0136	85.9061	-0.124980	0.303007	0.301177	-0.603946	0.530380	0.527560	-0.531694
Avg	84.9977	84.8430	-0.182040	0.282536	0.285026	0.881552	0.490167	0.494697	0.924175

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	85.3678	85.1502	-0.254897	0.272826	0.267045	-2.118933	0.466970	0.464750	-0.475405
2	85.6916	85.3931	-0.348342	0.272712	0.266512	-2.273461	0.474440	0.465080	-1.972852
3	85.9925	86.2661	0.318167	0.281818	0.270252	-4.104067	0.480550	0.464030	-3.437728
4	86.2067	86.2813	0.086536	0.273798	0.265939	-2.870364	0.472540	0.459020	-2.861133
5	85.6812	85.7651	0.097921	0.275314	0.264403	-3.963111	0.472690	0.457350	-3.245256
6	84.3032	84.4227	0.141750	0.278936	0.272611	-2.267545	0.491770	0.479450	-2.505236
7	85.9737	85.8041	-0.197270	0.272914	0.261832	-4.060620	0.468250	0.453310	-3.190603
8	86.0619	85.7732	-0.335456	0.268305	0.266256	-0.763683	0.467950	0.462420	-1.181750
9	84.3666	84.5719	0.243343	0.284571	0.275751	-3.099402	0.494930	0.481530	-2.707454
10	87.3301	86.4161	-1.046604	0.254251	0.259801	2.182882	0.444130	0.449310	1.166325
Min	84.3032	84.4227	0.141750	0.254251	0.259801	2.182882	0.444130	0.449310	1.166325
Max	87.3301	86.4161	-1.046604	0.284571	0.275751	-3.099402	0.494930	0.481530	-2.707454
Avg	85.6975	85.5844	-0.132034	0.273545	0.26704	-2.377785	0.473422	0.463625	-2.069401

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	86.1007	86.0216	-0.091869	0.284912	0.286774	0.653535	0.485690	0.489220	0.726801
2	85.7181	85.4201	-0.347651	0.284907	0.290261	1.879210	0.491390	0.499630	1.676876
3	86.3364	86.1719	-0.190534	0.273881	0.277093	1.172772	0.467870	0.473150	1.128519
4	84.1331	84.0361	-0.115294	0.287622	0.289385	0.612957	0.504570	0.507120	0.505381
5	86.0581	85.9602	-0.113760	0.278703	0.280719	0.723351	0.476510	0.480590	0.856225
6	85.9872	85.8513	-0.158047	0.279873	0.282198	0.830734	0.482290	0.485830	0.733998
7	86.4816	86.4276	-0.062441	0.279504	0.280975	0.526289	0.475470	0.478050	0.542621
8	86.3415	86.2329	-0.125780	0.277846	0.279377	0.551025	0.478050	0.479650	0.334693
9	84.8516	84.8497	-0.002239	0.282701	0.283662	0.339935	0.489230	0.491120	0.386321
10	86.8024	86.6601	-0.163936	0.277912	0.280375	0.886252	0.475230	0.480350	1.077373
Min	84.1331	84.0361	-0.115294	0.273881	0.277093	1.172772	0.467870	0.473150	1.128519
Max	86.8024	86.6601	-0.163936	0.287622	0.290261	0.917524	0.504570	0.507120	0.505381
Avg	85.8811	85.7632	-0.137306	0.280786	0.283082	0.817633	0.482630	0.486471	0.795848

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	83.6891	83.9472	0.308403	0.290354	0.286022	-1.491972	0.509110	0.499610	-1.866001
2	86.3628	86.2079	-0.179360	0.270605	0.272719	0.781212	0.466610	0.469330	0.582928
3	83.2249	83.2445	0.023551	0.294184	0.293048	-0.386153	0.514510	0.515190	0.132165
4	86.2637	86.0716	-0.222689	0.271155	0.273171	0.743486	0.468730	0.471020	0.488554
5	85.9517	85.8239	-0.148688	0.278801	0.280635	0.657817	0.476630	0.481190	0.956717
6	86.7701	86.6403	-0.149591	0.271603	0.273329	0.635486	0.465910	0.468230	0.497950
7	82.1112	82.2104	0.120812	0.309881	0.307301	-0.832578	0.545530	0.541430	-0.751563
8	86.0257	85.7501	-0.320369	0.272592	0.276245	1.340098	0.471110	0.477040	1.258729
9	85.1621	85.1402	-0.025716	0.283309	0.283614	0.107656	0.488320	0.488110	-0.043005
10	85.4011	84.7662	-0.743433	0.274024	0.283491	3.454807	0.478130	0.493250	3.162320
Min	82.1112	82.2104	0.120812	0.270605	0.272719	0.781212	0.465910	0.468230	0.497950
Max	86.7701	86.6403	-0.149591	0.309881	0.307301	-0.832578	0.545530	0.541430	-0.751563
Avg	85.0962	84.9802	-0.136328	0.281651	0.282958	0.463943	0.488459	0.490440	0.405561

No.	Leakage current (nA)					
	Before Test	After 200 hr	After 400 hr	After 600 hr	After 800 hr	After 1000 hr
1	2	2	2	3	2	2
2	2	2	2	2	2	2
3	2	2	2	2	2	2
4	2	2	2	2	2	2
5	2	2	2	2	2	2
6	2	2	2	2	2	2
7	2	2	2	2	2	2
8	2	2	2	2	2	2
9	2	2	2	2	2	2
10	2	2	2	2	2	2

No.	Leakage current (nA)					
	Before Test	After 200 hr	After 400 hr	After 600 hr	After 800 hr	After 1000 hr
1	2	2	1	2	2	2
2	2	2	1	2	2	2
3	2	2	1	2	2	2
4	2	2	1	2	2	2
5	2	2	1	2	2	2
6	2	2	1	2	2	2
7	2	2	1	2	2	2
8	2	2	1	2	2	2
9	2	2	1	2	2	2
10	2	2	1	2	2	2

\* \*印加電圧: 500Vdc

Original sample			After the high temperature test sample		
No.	Leakage current (uA)	Withstanding voltage (PASS/FAIL)	No.	Leakage current (uA)	Withstanding voltage (PASS/FAIL)
1	1	PASS	11	1	PASS
2	1	PASS	12	1	PASS
3	1	PASS	13	1	PASS
4	1	PASS	14	1	PASS
5	1	PASS	15	1	PASS
6	1	PASS			
7	1	PASS			
8	1	PASS			
9	1	PASS			
10	1	PASS			

\* \*印加電圧: 500Vdc

Original sample		After the high temperature test sample	
No.	Insulation resistance(MΩ)	No.	Insulation resistance(MΩ)
1	Over 100	11	Over 100
2	Over 100	12	Over 100
3	Over 100	13	Over 100
4	Over 100	14	Over 100
5	Over 100	15	Over 100
6	Over 100		
7	Over 100		
8	Over 100		
9	Over 100		
10	Over 100		



\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	94.7209	93.2358	-1.567869	0.060298	0.060388	0.149259	0.849660	0.860270	1.248735
2	94.6974	93.4428	-1.324852	0.063657	0.060466	-5.012803	0.884990	0.851120	-3.827162
3	94.9466	93.9283	-1.072498	0.062581	0.058567	-6.414087	0.874150	0.829960	-5.055196
4	95.0235	93.9461	-1.133825	0.063143	0.060594	-4.036869	0.874450	0.849520	-2.850935
5	93.1939	92.0192	-1.260490	0.064955	0.060098	-7.477484	0.924010	0.865510	-6.331100
6	95.0882	93.9738	-1.171965	0.064004	0.060901	-4.848134	0.886050	0.854120	-3.603634
7	95.2122	93.8984	-1.379865	0.062204	0.060098	-3.385634	0.868450	0.849660	-2.163625
8	94.4002	93.2384	-1.230718	0.064455	0.061522	-4.550462	0.897860	0.868960	-3.218765
9	94.7589	93.5655	-1.259407	0.061994	0.057228	-7.687841	0.869130	0.814880	-6.241874
10	93.0862	92.0029	-1.163760	0.075709	0.073505	-2.911147	1.069110	1.051190	-1.676161
Min	93.0862	92.0029	-1.163760	0.060298	0.057228	-5.091379	0.849660	0.814880	-4.093402
Max	95.2122	93.9738	-1.300674	0.075709	0.073505	-2.911147	1.069110	1.051190	-1.676161
Avg	94.5128	93.32512	-1.256634	0.0643	0.061337	-4.608554	0.899786	0.869519	-3.363800

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	93.2082	93.1884	-0.021243	0.065449	0.065347	-0.155847	0.924500	0.928450	0.427258
2	94.2425	94.0545	-0.199485	0.064331	0.066366	3.163327	0.905580	0.928290	2.507785
3	94.7718	94.5621	-0.221268	0.061166	0.062328	1.899748	0.846610	0.873130	3.132493
4	95.0341	94.8963	-0.145001	0.063529	0.064986	2.293441	0.885320	0.901020	1.773370
5	94.5276	94.2552	-0.288170	0.059824	0.062052	3.724258	0.824930	0.871140	5.601687
6	94.2115	93.9119	-0.318008	0.060467	0.063152	4.440439	0.854560	0.886520	3.739936
7	93.2411	93.1001	-0.151221	0.065278	0.066112	1.277613	0.921150	0.941380	2.196168
8	94.2969	94.1789	-0.125137	0.060997	0.062606	2.637835	0.852110	0.876970	2.917464
9	92.2146	91.8335	-0.413275	0.058329	0.061156	4.846646	0.839860	0.881030	4.902007
10	94.2450	94.1011	-0.152687	0.061621	0.062782	1.884098	0.859740	0.879120	2.254170
Min	92.2146	91.8335	-0.413275	0.058329	0.061156	4.846646	0.824930	0.871140	5.601687
Max	95.0341	94.8963	-0.145001	0.065449	0.066366	1.401091	0.924500	0.941380	1.825852
Avg	93.9993	93.8082	-0.203331	0.062099	0.063689	2.559779	0.871436	0.896705	2.899697

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	92.8789	92.4431	-0.469213	0.063650	0.059704	-6.199529	0.863130	0.860840	-0.265313
2	93.9935	93.7346	-0.275445	0.064072	0.061688	-3.720814	0.897970	0.863150	-3.877635
3	92.0825	91.8108	-0.295061	0.061194	0.058701	-4.073929	0.879790	0.848470	-3.559940
4	94.5446	94.0515	-0.521553	0.064436	0.063211	-1.901111	0.897290	0.884670	-1.406457
5	93.4778	93.1138	-0.389397	0.081258	0.079226	-2.500677	1.149970	1.133210	-1.457429
6	94.8327	94.3425	-0.516910	0.063272	0.061333	-3.064547	0.883390	0.855820	-3.120932
7	94.6812	94.1815	-0.527771	0.063031	0.060645	-3.785439	0.876230	0.853950	-2.542711
8	95.3121	94.7012	-0.640947	0.063408	0.062728	-1.072420	0.881020	0.869910	-1.261038
9	93.5803	93.1438	-0.466444	0.064242	0.061888	-3.664269	0.903890	0.881260	-2.503623
10	94.2537	93.7331	-0.552339	0.063968	0.062282	-2.635693	0.897650	0.873680	-2.670306
Min	92.0825	91.8108	-0.295061	0.061194	0.058701	-4.073929	0.863130	0.848470	-1.698470
Max	95.3121	94.7012	-0.640947	0.081258	0.079226	-2.500677	1.149970	1.133210	-1.457429
Avg	93.9637	93.5256	-0.466286	0.065253	0.063141	-3.237394	0.913033	0.892496	-2.249316

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	94.5555	94.3744	-0.191528	0.065170	0.065774	0.926807	0.915380	0.925040	1.055299
2	94.3573	94.2906	-0.070689	0.064882	0.065478	0.918591	0.904290	0.915170	1.203154
3	94.9221	94.8003	-0.128316	0.061028	0.061594	0.927443	0.852930	0.862840	1.161877
4	93.3810	93.3473	-0.036089	0.073629	0.074149	0.706243	1.037560	1.044350	0.654420
5	94.9506	94.9297	-0.022011	0.062136	0.064947	4.523947	0.908730	0.906960	-0.194777
6	94.3384	94.2883	-0.053107	0.067084	0.067087	0.004472	0.935660	0.935730	0.007481
7	94.5076	94.3919	-0.122424	0.063635	0.064964	2.088473	0.894550	0.912970	2.059136
8	94.5438	94.4154	-0.135810	0.066723	0.067042	0.478096	0.928570	0.933640	0.546001
9	95.0315	94.8174	-0.225294	0.063012	0.064177	1.848854	0.878640	0.896240	2.003096
10	94.5461	94.4603	-0.090749	0.065482	0.065957	0.725390	0.911460	0.919010	0.828341
Min	93.381	93.3473	-0.036089	0.061028	0.061594	0.927443	0.852930	0.862840	1.161877
Max	95.0315	94.9297	-0.107122	0.073629	0.074149	0.706243	1.037560	1.044350	0.654420
Avg	94.5134	94.4116	-0.107741	0.065278	0.066117	1.284964	0.916777	0.925195	0.918217

\* 120 Hzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	94.9411	94.7624	-0.188222	0.063451	0.062602	-1.338040	0.886860	0.877050	-1.106150
2	94.5936	94.2604	-0.352244	0.065773	0.066343	0.866617	0.915220	0.927770	1.371255
3	92.2638	91.9522	-0.337727	0.060968	0.061982	1.663168	0.875270	0.891340	1.836005
4	94.4303	94.1239	-0.324472	0.065484	0.066128	0.983446	0.910990	0.925780	1.623508
5	93.7636	93.5351	-0.243698	0.065805	0.065659	-0.221868	0.929770	0.930050	0.030115
6	91.8462	91.6166	-0.249983	0.088052	0.090014	2.228229	1.257240	1.290150	2.617639
7	92.3388	92.1648	-0.188436	0.060867	0.061564	1.145120	0.867450	0.882910	1.782235
8	91.9674	91.6853	-0.306739	0.063507	0.064986	2.328877	0.915020	0.934670	2.147494
9	94.8412	94.5941	-0.260541	0.064994	0.065471	0.733914	0.902730	0.915110	1.371396
10	94.6507	94.3393	-0.328999	0.067325	0.067734	0.607501	0.940870	0.946190	0.565434
Min	91.8462	91.6166	-0.249983	0.060867	0.061564	1.145120	0.867450	0.877050	1.106692
Max	94.9411	94.7624	-0.188222	0.088052	0.090014	2.228229	1.257240	1.290150	2.617639
Avg	93.5637	93.3034	-0.278164	0.066623	0.067248	0.939171	0.940142	0.952102	1.272148

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	82.3083	81.7511	-0.676967	0.338739	0.326801	-3.524247	0.575210	0.571910	-0.573704
2	82.4759	82.6013	0.152044	0.341958	0.320667	-6.226203	0.597510	0.564140	-5.584844
3	82.2104	82.6131	0.489841	0.349772	0.325601	-6.910502	0.597440	0.560340	-6.209829
4	82.8476	82.7210	-0.152811	0.341891	0.326913	-4.380928	0.591770	0.571220	-3.472633
5	79.7435	80.8616	1.402121	0.365522	0.320877	-12.214039	0.638970	0.569670	-10.845580
6	82.7531	82.7996	0.056191	0.341719	0.324229	-5.118240	0.592260	0.566460	-4.356195
7	82.5561	82.4481	-0.130820	0.344411	0.327067	-5.035844	0.584590	0.565160	-3.323697
8	82.3610	82.1666	-0.236034	0.342527	0.323913	-5.434316	0.598010	0.572090	-4.334376
9	82.1199	82.7761	0.799075	0.345326	0.310714	-10.022993	0.591770	0.533270	-9.885597
10	77.8011	77.4825	-0.409506	0.393566	0.377044	-4.198025	0.702710	0.681240	-3.055314
Min	77.8011	77.4825	-0.409506	0.338739	0.310714	-8.273331	0.575210	0.533270	-7.291250
Max	82.8476	82.7996	-0.057938	0.393566	0.377044	-4.198025	0.702710	0.681240	-3.055314
Avg	81.7177	81.8221	0.127769	0.350543	0.328383	-6.321762	0.607024	0.575550	-5.184968

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	80.6481	79.9088	-0.916699	0.350777	0.362111	3.231113	0.624320	0.634210	1.584124
2	81.1661	80.8315	-0.412241	0.355125	0.359954	1.359803	0.612460	0.629390	2.764262
3	83.8044	82.0251	-2.123158	0.319551	0.347412	8.718796	0.558660	0.598120	7.063330
4	82.1827	82.0446	-0.168040	0.351213	0.354471	0.927642	0.602760	0.614970	2.025682
5	84.8145	82.1981	-3.084850	0.29748	0.337791	13.550827	0.527150	0.584540	10.886844
6	82.3354	81.7957	-0.655490	0.333405	0.342214	2.642132	0.575250	0.601480	4.559757
7	80.5031	79.3412	-1.443298	0.354908	0.372822	5.047505	0.627290	0.653140	4.120901
8	83.0529	81.8711	-1.422949	0.327931	0.344577	5.076068	0.573450	0.599930	4.617665
9	81.3357	80.2077	-1.386845	0.318057	0.335951	5.626036	0.560850	0.597060	6.456272
10	82.7413	81.8032	-1.133775	0.330416	0.345438	4.546390	0.577580	0.602080	4.241837
Min	80.5031	79.3412	-1.443298	0.29748	0.335951	12.932298	0.527150	0.584540	10.886844
Max	84.8145	82.1981	-3.084850	0.355125	0.372822	4.983316	0.627290	0.653140	4.120901
Avg	82.2584	81.2027	-1.283419	0.333886	0.350274	4.908198	0.583977	0.611492	4.711658

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	81.2601	80.9551	-0.375338	0.329789	0.328049	-0.527610	0.576380	0.575330	-0.182171
2	81.9637	82.9501	1.203460	0.340432	0.318954	-6.309043	0.596610	0.562330	-5.745797
3	80.5297	81.0374	0.630451	0.333794	0.318911	-4.458738	0.590410	0.562620	-4.706899
4	82.0107	82.1767	0.202413	0.346357	0.333726	-3.646815	0.604340	0.586220	-2.998312
5	75.0552	75.1711	0.154420	0.436477	0.427665	-2.018892	0.773550	0.756780	-2.167927
6	82.2403	83.1017	1.047418	0.345691	0.325053	-5.970072	0.594360	0.567440	-4.529242
7	82.7249	82.5111	-0.258447	0.335011	0.329616	-1.610395	0.581930	0.568540	-2.300964
8	82.5180	82.8615	0.416273	0.348908	0.335084	-3.962076	0.596150	0.581890	-2.392015
9	81.0556	80.9401	-0.142495	0.348256	0.340552	-2.212166	0.612340	0.594760	-2.870954
10	81.5666	82.3072	0.907970	0.349095	0.328903	-5.784099	0.604030	0.578720	-4.190189
Min	75.0552	75.1711	0.154420	0.329789	0.318911	-3.298473	0.576380	0.562330	-2.437628
Max	82.7249	83.1017	0.455486	0.436477	0.427665	-2.018892	0.773550	0.756780	-2.167927
Avg	81.0925	81.4012	0.380701	0.351381	0.338651	-3.622763	0.613010	0.593463	-3.188692



\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	80.8818	80.5604	-0.397370	0.365431	0.369592	1.138655	0.631480	0.637770	0.996073
2	81.8204	81.4711	-0.426911	0.348524	0.352103	1.026902	0.608420	0.618130	1.595937
3	82.4857	82.1551	-0.400797	0.343020	0.348275	1.531981	0.587530	0.596660	1.553963
4	77.6213	77.3811	-0.309451	0.402845	0.406717	0.961164	0.714750	0.720990	0.873033
5	81.1547	81.1823	0.034009	0.368956	0.367712	-0.337168	0.633760	0.631550	-0.348712
6	80.6553	80.8004	0.179901	0.368431	0.363541	-1.327250	0.642410	0.642220	-0.029576
7	81.4465	80.9782	-0.574979	0.355336	0.362703	2.073249	0.611330	0.627190	2.594343
8	81.1137	80.9113	-0.249526	0.364424	0.366719	0.629761	0.634260	0.638610	0.685839
9	82.1325	81.5865	-0.664779	0.351506	0.359324	2.224144	0.600740	0.617320	2.759929
10	81.6413	81.5113	-0.159233	0.354875	0.356831	0.551180	0.618810	0.626680	1.271796
Min	77.6213	77.3811	-0.309451	0.34302	0.348275	1.531981	0.587530	0.596660	1.553963
Max	82.4857	82.1551	-0.400797	0.402845	0.406717	0.961164	0.714750	0.720990	0.873033
Avg	81.0953	80.8538	-0.297859	0.362335	0.365352	0.832628	0.628349	0.635712	1.171801

\* 1 kHzで測定

No.	Capacitance (uF)			Tan ( $\delta$ )			ESR (ohm)		
	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)	Before Test	After test	Change rate (%)
1	81.6684	81.7321	0.077998	0.359544	0.356406	-0.872772	0.615540	0.606760	-1.426390
2	81.6037	80.9392	-0.814301	0.355737	0.362861	2.002603	0.619710	0.632850	2.120347
3	80.4121	79.8666	-0.678380	0.339443	0.345802	1.873363	0.599440	0.613710	2.380555
4	81.5515	80.6203	-1.141855	0.357732	0.368273	2.946619	0.624200	0.642710	2.965396
5	80.3333	80.1313	-0.251452	0.365133	0.365768	0.173909	0.636530	0.636660	0.020423
6	72.2167	70.7181	-2.075143	0.466821	0.485977	4.103500	0.852820	0.886510	3.950423
7	81.0034	80.0743	-1.146989	0.331393	0.345715	4.321757	0.591180	0.611110	3.371224
8	79.4502	79.1513	-0.376211	0.349706	0.352021	0.661985	0.620060	0.631930	1.914331
9	81.6722	80.9042	-0.940344	0.359267	0.369388	2.817125	0.622160	0.637760	2.507394
10	80.0888	80.1134	0.030716	0.382912	0.379472	-0.898379	0.660060	0.661770	0.259067
Min	72.2167	70.7181	-2.075143	0.331393	0.345715	4.321757	0.591180	0.606760	2.635407
Max	81.6722	81.7321	0.073342	0.466821	0.485977	4.103500	0.852820	0.886510	3.950423
Avg	80.0000	79.4251	-0.718687	0.366769	0.373168	1.744832	0.644170	0.656177	1.863949

No.	Leakage current (nA)					
	Before Test	After 200 hr	After 400 hr	After 600 hr	After 800 hr	After 1000 hr
1	2	2	2	2	2	2
2	2	2	1	2	2	2
3	2	2	2	2	2	2
4	2	2	2	2	2	2
5	2	2	2	2	2	2
6	2	2	1	2	2	2
7	2	2	2	2	2	2
8	2	2	1	2	2	2
9	2	2	2	2	2	2
10	2	2	1	2	2	2

No.	Leakage current (nA)					
	Before Test	After 200 hr	After 400 hr	After 600 hr	After 800 hr	After 1000 hr
1	2	2	1	2	2	2
2	2	2	1	2	2	2
3	2	2	1	2	2	2
4	2	2	1	2	2	2
5	2	2	1	2	2	2
6	2	2	1	2	2	2
7	2	2	1	2	2	2
8	2	2	1	2	2	2
9	2	2	1	2	2	2
10	2	2	1	2	2	2

\* \*印加電圧: 500Vdc










Original sample			After the high temperature test sample		
No.	Leakage current (uA)	Withstanding voltage (PASS/FAIL)	No.	Leakage current (uA)	Withstanding voltage (PASS/FAIL)
1	1	PASS	11	1	PASS
2	1	PASS	12	1	PASS
3	1	PASS	13	1	PASS
4	1	PASS	14	1	PASS
5	1	PASS	15	1	PASS
6	1	PASS			
7	1	PASS			
8	1	PASS			
9	1	PASS			
10	1	PASS			

\* \*印加電圧: 500Vdc



Original sample		After the high temperature test sample	
No.	Insulation resistance(MΩ)	No.	Insulation resistance(MΩ)
1	Over 100	11	Over 100
2	Over 100	12	Over 100
3	Over 100	13	Over 100
4	Over 100	14	Over 100
5	Over 100	15	Over 100
6	Over 100		
7	Over 100		
8	Over 100		
9	Over 100		
10	Over 100		

# III. X-ray analyses




Specimen	X-ray analyses			
A				
B				
C				






Scene coordinate system  
63.07  $\mu\text{m}$



Top 1 Scene coordinate system  
16.84  $\mu\text{m}$



Right 1

Scene coordinate system  
-2024.75  $\mu\text{m}$





63%  
Front 1




66%


67%



Scene coordinate system  
139.72  $\mu\text{m}$




Top 1 Scene coordinate system  
190.46  $\mu\text{m}$






Right 1

Scene coordinate system  
-1230.54  $\mu\text{m}$




64%  
Front 1






Scene coordinate system  
59.38  $\mu\text{m}$




Top 1 Scene coordinate system  
91.78  $\mu\text{m}$




Right 1

Scene coordinate system  
-562.09  $\mu\text{m}$



Front 1

64% 75%






# IV. SEM analyses






Sample

SEM analyses



A



B





C










- Front






- Back





## • Front





## • Back






- Front






- Back





## • Front





## • Back






- Front






- Back



## • Front



## • Back



# V. Summary and conclusions



- 3社のSMD type capacitorにて数種の環境試験(高温, 低温, 熱衝撃, 振動, 耐湿性), 漏れ電流測定, 耐電圧試験, 絶縁抵抗試験, 内部構造分析(非破壊分析), 内部電極の成分分析(破壊分析)を行う。
- 3社のコンデンサーの内部構造には差がない。
- B社のコンデンサーが環境試験による特性変化が一番小さい。すなわち、外部環境のストレスが一番強いと言える。
- A社のコンデンサーは相対的に熱衝撃と振動環境に弱い。
- C社のコンデンサーは相対的に低温と湿気環境に弱い。
- 高温試験によるCapacitance(@1 kHz)の変化はC社の製品が一番小さい。(C<A<B)
- 低温試験によるCapacitance(@1 kHz)の変化はB社の製品が一番大きい。(B<A<C)
- 熱衝撃試験によるCapacitance(@1 kHz)の変化はB社の製品が一番小さい。(B<C<A)
- 振動試験によるCapacitance(@1 kHz)の変化はB社の製品が一番小さい。(B<C<A)
- 高度湿度試験によるCapacitance(@1 kHz)の変化はB社の製品が一番小さい。(B<A<C)



## ■面実装型アルミ電解コンデンサ各種試験結果比較

KETIにて実施しましたアルミ電解コンデンサ製品3社の各種試験結果を比較して纏めました。  
特に大きな問題は散見されず性能/品質は安定していると推測できます。

試験項目		A: Samwha	B: Su'scon	C: NICHICON
X線解析		異常なし/異物なし	異常なし/異物なし	異常なし/異物なし
SEM観察/成分分析		異常なし/異物なし	異常なし/異物なし	異常なし/異物なし
高温保存試験 (105°C/16時間)	容量変化最大値	-0.79%	-0.66%	1.57%
	容量変化平均値	-0.37%	-0.26%	1.07%
低温保存試験 (-40°C/2時間)	容量変化最大値	-0.26%	-0.20%	-0.41%
	容量変化平均値	-0.02%	-0.03%	-0.02%
サーマルショック試験 (-40°C~105°C変化/30分間 隔5サイクル)	容量変化最大値	-0.35%	-0.82%	-0.64%
	容量変化平均値	-0.02%	-0.10%	-0.29%
高湿度保存試験 (40°C/93%RH/500時間)	容量変化最大値	-0.97%	-0.74%	-0.35%
	容量変化平均値	-0.42%	0.02%	-0.18%
過電圧印加試験(500V)		オープン	オープン	オープン

